South Chapel N - Proposed Roof Form

- 1. Provide and install new tanalised timber structure to accommodate revised roof and gutter layouts as shown.
- 2. Provide and fix new 8lb sand-cast lead roof covering and parapet gutter lining incorporating continuous ventilation along the intermediate drip and the gutter upstand, with new code 5 lead cover flashings to all abutments.
- Reinstate lightning conductor tape to south west corner. 3.
- 4. Installation of further ventilation subject to success of trials.

Note:

Drawings based on 2008 survey.

Abutment dimensions vary across the side chapel roofs, and in some instances, across their length. All dimensions to be checked on site.













Existing view looking west



TEL: 01223 472 237 WWW.CAROE.COM

ARCHITECTURE

ONDON EC4M 8AD EL: 02072 468 341

Section B-B' 1:50

